



NOTES: DUCTILE IRON PIPE SHALL EXTEND OUT A MINIMUM OF 36" PAST THE FOUNDATION. ALTERNATIVELY, THE PLASTIC PIPE MAY BE EXTENDED IN UNDER THE FOUNDATION PROVIDING THE PIPE IS ENCASED IN CONCRETE BELOW THE FOUNDATION AND 24" OUT IN BOTH DIRECTIONS.

WATER ENTRY WITH SINGLE WET SYSTEM

(DO NOT SCALE)

- NOTES:
- 1) ALL VALVES INDICATED ARE UL/FM APPROVED
 - 2) IF ADDITIVES ARE PRESENT SUCH AS ANTI-FREEZE ALL BACKFLOW DEVICES ARE REDUCED PRESSURE PRINCIPAL
 - 3) ALL BACKFLOW DEVICES ARE TO BE TAGGED AND TESTED ANNUALLY.